



2025 Hamilton System Water Quality Report*

PWSID#: NJ1103001

*Este informe contiene información muy importante sobre su agua de beber.
Tradúzcalo o hable con alguien que lo entienda bien.*

About Your Drinking Water

Aqua New Jersey (Aqua) is pleased to provide you with important information about your drinking water in this 2025 Consumer Confidence Report. The report summarizes the quality of water provided in 2025 - including details about water sources, what the water at your tap contains, and how it compares to standards set by regulatory agencies. We are pleased to report that we were in compliance with all water quality regulations (MCL/AL) in 2025. Although the report lists only those regulated substances that were detected in your water, we test for more than what is reported. This report is only a summary of our testing during 2025.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 800.426.4791.

Contaminant	Year Sampled	MCL	MCLG	Range Detected	Highest Level Detected	Compliance Achieved	Typical Source
Inorganic Contaminants							
Barium (ppm)	2023	2	2	0.059 - 0.139	0.133	Yes	Erosion of natural deposits
Nitrate (ppm)	2025	10	10	<1 – 4.4	4.4	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Fluoride (ppm)	2023	4	4	0.41 – 0.71	0.71	Yes	Erosion of natural deposits.
Radionuclides - The range is for all individual sample results. The highest level detected is the highest RAA among all sources tested.							
Gross Alpha (pCi/L)	2025	15	0	<3 – 9.99	9.83	Yes	Erosion of natural deposits
Combined Radium (pCi/L)	2025	5	0	<1 – 4.7	3.88	Yes	
Stage 2 Treatment By-products - Range is for individual sample results. Highest level detected is the highest LRAA for all sample locations.							
TTHMs [Total Trihalomethanes] (ppb)	2025	80	NA	3.3 – 21.8	15.87	Yes	By-product of drinking water disinfection
Haloacetic Acids [HAAs] (ppb)	2025	60	NA	0-4	5.1	Yes	
Disinfectants - The range is for all individual sample results. The highest level detected is the highest annual average detected.							
Chlorine (ppm)	2025	MRDL = 4	MRDLG = 4	0.80 – 1.00	0.98	Yes	Water additive used to control microbes

Aqua New Jersey - Hamilton System, PWSID#: NJ1103001

Volatile Organics – All values are in ppb.							
Contaminant	Year Sampled	MCL	MCLG	Range Detected	Highest Level Detected	Compliance Achieved	Typical Source
Methyl-tertiary Butyl Ether (MtBE)	2025	70	NA	<0.5 – 1.2	1.2	Yes	Octane enhancer in gasoline
Tetrachloroethylene	2025	1	NA	<0.5 – 0.7	0.7	Yes	Discharge from factories and dry cleaners.
PFAs – All values are in ppt. The range is for all individual sample results. The highest level detected is the highest RAA.							
Perfluorooctane sulfonic Acid (PFOS) – All values are in ppt. The range is for all individual sample results. The highest level detected is the highest RAA.							
Perfluorooctane sulfonic Acid (PFOS)	2025	13	13	<2.0 – 11	10.63	Yes	Manmade chemical used in products to make them stain, grease, heat, and water resistant.
Perfluorooctanoic Acid (PFOA) – All values are in ppt. The range is for all individual sample results. The highest level detected is the highest RAA.							
Perfluorooctanoic Acid (PFOA)	2025	14	14	<2.0 – 12	11	Yes	Perfluorinated aliphatic carboxylic acid; used for its emulsifier and surfactant properties in or as fluoropolymer (such as Teflon), Fire-Fighting foams, cleaners, cosmetics, greases and lubricants, paints, polishes, adhesives, and photographic films.
Perfluorononanoic acid (PFNA) – All values are in ppt. The range is for all individual sample results. The highest level detected is the highest RAA.							
Perfluorononanoic acid (PFNA)	2025	13	13	<2.0 – 2.2	1.65	Yes	Perfluorinated aliphatic carboxylic acid; used for its emulsifier and surfactant properties in or as fluoropolymer (such as Teflon), Fire-Fighting foams, cleaners, cosmetics, greases and lubricants, paints, polishes, adhesives, and photographic films.

Fluoride: Fluoride may help prevent tooth decay if administered properly to children but can be harmful in excess. Customers in this System receive water from a fluoridated water supply. For more information about fluoride in your tap water, call Aqua at 877.WTR.AQUA (877.987.2782). This information may be helpful to you, your pediatrician, or your dentist in determining whether fluoride supplements or treatment are appropriate.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, may be more than one year old.

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals, and synthetic organic chemicals. Our system received monitoring waivers for asbestos and synthetic organic chemicals. No volatile organics were detected.

Our water systems are designed and operated to deliver water to our customers' plumbing systems that complies with state and federal drinking water standards. This water is disinfected using chlorine, but it is not necessarily sterile. Customers' plumbing, including treatment devices, might remove, introduce, or increase contaminants in tap water. All customers, and operators of facilities like hotels

Aqua New Jersey - Hamilton System, PWSID#: NJ1103001

and institutions serving susceptible populations (like hospitals and nursing homes), should properly operate and maintain the plumbing systems in these facilities. You can obtain additional information from the EPA's Safe Drinking Water Hotline at 800.426.4791.

Secondary Contaminants	Year Sampled	Recommended Upper Limit (RUL)	Range Detected	Highest Level Detected	Compliance Achieved	Typical Source
Manganese** (ppm)	2023	RUL = 0.05	<0.01 - 0.08	0.08	Yes	Erosion of natural deposits
Hardness (ppm)	2023	RUL = 250	<10 - 49	49	Yes	
Aluminum (ppm)	2023	RUL = 0.2	<0.01 - 0.09	0.09	Yes	
Sodium*** (ppm)	2025	RUL = 50	71.1 – 75.4	75.4	No	Erosion of natural deposits; use of sodium containing water treatment chemicals

**The recommended upper limit for manganese is based on staining of laundry. Manganese is an essential nutrient, and toxicity is not expected from high levels which would not be encountered in drinking water.

***For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the recommended upper limit may be a concern to individuals on a sodium restricted diet.

Tap water samples were collected from homes in the service area for lead and copper testing.

Contaminant	Year Sampled	Action Level	MCLG	Amount Detected (90 th percentile)	Homes Above Action Level	Range	Compliance Achieved	Typical Source
Copper (ppm)	2023	1.3	1.3	0.2	0	<0.05 – 0.26	Yes	Corrosion of household plumbing
Lead (ppb)	2023	15	0	<2.0	0	<2.0 – 8.2	Yes	

Lead can cause serious health problems, especially for pregnant women and young children. Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Aqua NJ is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact AquaNJ_Lead@aquaaamerica.com. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. Aqua NJ has prepared a Service Line Inventory and it is available at www.aquawater.com/leadmap.

Testing is essential because you cannot see, taste or smell lead in drinking water. *If lead was detected, the Landlords must distribute this information to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail or email and posting the information in a prominent location at the entrance of each rental premises, pursuant to section 3 of P.L. 2021, c. 82 (C.58:12A-12.4 et seq.).*

Aqua conducted unregulated contaminant monitoring as required by the USEPA during 2025. Contaminants in USEPA's current unregulated contaminant monitoring list include 29 per- and polyfluoroalkyl substances (PFAS) and lithium. Below is a table of the results for contaminants that were detected. All other contaminants tested were not detected.

UCMR5- Unregulated Contaminants Detected During 2025:			
Unregulated Contaminant	Average Detection	Range of Detections	MCL
Entry Point Samples			

Aqua New Jersey - Hamilton System, PWSID#: NJ1103001

Lithium, ppb	5.93	ND – 27.5	NA
Perfluorohexanoic acid (PFHxA), ppt	2.5	ND – 5.4	NA
Perfluoroheptanoic acid (PFHpA), ppt	1.4	ND – 3.4	NA
Perfluoropentanoic acid (PFPeA), ppt	2.3	ND – 4.6	NA
Perfluorohexanesulfonic acid (PFHxS), ppt	3.0	ND – 10.4	NA

Definitions:

- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Locational Running Annual Average (LRAA):** The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.
- **Running Annual Average (RAA):** The average of a year of monthly or quarterly sample results
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **Treatment Technique:** A required process intended to reduce the level of a contaminant in drinking water.
- **NA:** Not applicable.
- **ND:** Not detected.
- **pCi/L, picoCuries/ Liter:** A unit of concentration for radioactive contaminants.
- **ppt:** A unit of concentration equal to one part per trillion
- **ppb:** A unit of concentration equal to one part per billion.
- **ppm:** A unit of concentration equal to one part per million.
- **PWSID:** Public water supply identification number.

Violation(s):

2025 - 10247: Lead Consumer Notice – Aqua NJ submitted the Lead Copper Reporting form to the NJDEP after the NJDEP required due date. There is no further action for this violation.

Definitions:

- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Locational Running Annual Average (LRAA):** The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.
- **Running Annual Average (RAA):** The average of a year of monthly or quarterly sample results
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **Treatment Technique:** A required process intended to reduce the level of a contaminant in drinking water.
- **NA:** Not applicable.
- **ND:** Not detected.
- **pCi/L, picoCuries/ Liter:** A unit of concentration for radioactive contaminants.

Aqua New Jersey - Hamilton System, PWSID#: NJ1103001

- **ppt:** A unit of concentration equal to one part per trillion
- **ppb:** A unit of concentration equal to one part per billion.
- **ppm:** A unit of concentration equal to one part per million.
- **PWSID:** Public water supply identification number.

Sources of Supply

Water for the Hamilton system, serving Hamilton Township, Washington Township, Chesterfield Township and Upper Freehold Township, comes from five wells in the Potomac-Raritan-Magothy aquifer. The system also interconnects with Trenton Water. The Consumer Confidence Report for Trenton can be found at www.trentonnj.org. The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system is available at www.nj.gov/dep/watersupply/swap or by contacting the NJDEP, Bureau of Safe Drinking Water at 609.292.5550.

Sources	Pathogens	Nutrients	Pesticides	Volatile Organic Compounds	Inorganics	Radionuclides	Radon	Disinfection Byproduct Precursors
5 Wells	Low to High	High	Low to Medium	High	High	High	Low to Medium	Medium

The sources overall have a medium to high risk of significant contamination. **If a system is rated highly susceptible for a contamination category, it does not mean a customer is or will be consuming contaminated drinking water.** The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. If you have questions regarding the source water assessment report or summary, please contact the Bureau of Safe Drinking Water at watersupply@dep.nj.gov or 609.292.5550.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline at 800.426.4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources, such as agriculture, stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organics, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Public Participation

Questions from our customers are welcomed and encouraged. For further information about this report or your water quality, please call Aqua New Jersey at 877.WTR.AQUA (877.987.2782) or visit our website at AquaWater.com. We want our valued customers to be informed about their water utility.

Aqua New Jersey - Hamilton System, PWSID#: NJ1103001

How you can help conserve water:

Kitchen & Laundry Room	
✓	Run full loads in your dishwasher and clothes washer. Save even more by using a shorter cycle.
✓	Check faucets and pipes for leaks. Even small leaks over a long period of time can add up to large amounts of water wasted.
Bathroom	
✓	Check your toilets for leaks. Put a few drops of food coloring in your toilet tank. Do not flush the toilet. If color begins to appear in the bowl, you have a leak that should be repaired immediately. Toilet leaks can cause elevated water usage, which will increase both your water and sewer bill.
✓	Take shorter showers. You can waste five to ten gallons per minute.
✓	Install water-saving toilets, faucet aerators, and shower heads to reduce water consumption while showering.
✗	Don't allow water to run while brushing your teeth, washing your hands, or shaving.
Outside	
✓	Water your lawn in the early morning to prevent evaporation. Water your lawn long enough to soak down into the roots but less frequently. Watering your lawn frequently without soaking the roots will encourage a shallow root system. Watering your lawn in the evening may cause fungus growth.
✓	Water plants before 9 A.M. and after 7 P.M.
✓	Plant drought resistant trees and plants. There are many beautiful trees and plants that require far less water than other species. Put a layer of mulch around your plants and trees. Mulch will slow evaporation of moisture and discourage weed growth.
✓	Use a broom to clean driveways and sidewalks. Using a hose to wash driveways and sidewalks will result in wasted water.
✗	Don't allow your garden hose to run while washing your car. Use the hose only to wet and rinse the car.

* This notice contains regulatorily required or recommended language, and nothing herein is, is intended as, nor should be construed as, a promise of or contract for payment or reimbursement of expenses incurred for any action you take on account of this notice.